



APPLICATION TO DIG NEAR POWER POLES

Consent No: _____

INSTRUCTIONS FOR SAFE EXCAVATION NEAR POWER POLES ELECTRICITY (SAFETY) REGULATIONS 2010 - REGULATION 17

INSTRUCTIONS

Prior written consent is required from Alpine Energy Ltd if you are excavating:

- (a) at a greater depth than 300 mm within 2.2 m of the pole or stay wire of the line; or
- (b) at a greater depth than 750 mm between 2.2 m and 5 m of the pole or stay wire; or
- (c) and creating an unstable batter.

Written consent from Alpine Energy Ltd is not required for:

- (a) vertical holes, not exceeding 500 mm diameter, beyond 1.5 m from a pole or stay wire.
- (b) normal agricultural cultivation
- (c) the repair, sealing, or resealing of the existing surface of any road, footpath, or driveway.

CONTRACTOR DETAILS

NAME OF CONTRACTOR: _____

ADDRESS OF CONTRACTOR: _____

MOBILE NO: _____ FAX: _____

FULL NAME OF OPERATOR: _____

STREET OR LOCALITY WHERE WORK IS TO BE CARRIED OUT:

5 DIGIT POLE ID NUMBERS: _____

EXCAVATION DEPTH: _____

DISTANCE FROM NEAREST FACE OF POLE: _____

ESTIMATED TIMES: _____ DATE WORK TO BE CARRIED OUT: _____

We/I have procedures to carry out this work safely and within the above safeguards and are competent to do so.

B4UDIG Requested Y/N B4UDIG Job Number _____

SIGNATURE OF CONTRACTOR: _____

APPROVED BY ALPINE ENERGY LTD

Special safeguards to be observed:

SIGNATURE OF ISSUING OFFICER: _____

DATE: _____ DESIGNATION: _____

File Number _____